

Fire Department Water Tanker Shuttle Accreditation

Presented To: East Hawkesbury, Municipality of

ACCREDITED FIRE STATIONS

F.S #1 St Eugene (6)

F.S #2 Ste. Anne (Dwelling Only)

F.S #3 Chute de Blondeau (Dwelling Only)

Date Test Passed: September 7th 2019

Flow Achieved: 626 I.G.P.M. 2,850 LITERS/MIN.

Two (2) Hour Test Time



Signed: Elaine Rose
Elaine Rose
Partner

This Certificate Expires on: September 1st 2024